

<b>ORANGE &amp; ROCKLAND UTILITIES, INC.</b>	<b>Coordinated Electric System Interconnect Review</b>	Doc. # <b>CDG-00352</b> Page 1 of 9
	<b>Distributed Energy Resources - NYSSIR</b>	Version 1.1 – 8/14/18

**For**  
**Interconnection Customer: Forefront Solar LLC**  
**Applicant: Forefront Power LLC**  
**5000 kW Photovoltaic (PV) Generator System**  
**279 Maple Ave., Goshen, NY 10924**

**Interconnection to Orange & Rockland Utilities, Inc.**  
**NY Central Division**  
**South Goshen Substation**  
**13.2 kV Feeder 89-2-13**

---

THIS DOCUMENT AND ANY ATTACHMENTS HERETO ("DOCUMENT") IS MADE AVAILABLE BY ORANGE & ROCKLAND UTILITIES UPON AND SUBJECT TO THE EXPRESS UNDERSTANDING THAT: (A) NEITHER ORANGE & ROCKLAND UTILITIES NOR ANY OF ITS OFFICERS, DIRECTORS, AFFILIATES, AGENTS, OR EMPLOYEES MAKES ANY WARRANTY, ASSURANCE, GUARANTY, OR REPRESENTATION WITH RESPECT TO THE CONTENTS OF THE DOCUMENT OR THE ACCURACY OR COMPLETENESS OF THE INFORMATION CONTAINED OR REFERENCED IN THE DOCUMENT, AND (B) ORANGE & ROCKLAND UTILITIES, ITS OFFICERS, DIRECTORS, AFFILIATES, AGENTS, AND EMPLOYEES SHALL NOT HAVE ANY LIABILITY OR RESPONSIBILITY FOR INACCURACIES, ERRORS, OR OMISSIONS IN, OR ANY BUSINESS OR POLICY DECISIONS MADE BY ANY DIRECT OR INDIRECT RECIPIENT IN RELIANCE ON, THIS DOCUMENT OR THE INFORMATION CONTAINED OR REFERENCED THEREIN; ALL SUCH LIABILITY IS EXPRESSLY DISCLAIMED.

---

<b>ORANGE &amp; ROCKLAND UTILITIES, INC.</b>	<b>Coordinated Electric System Interconnect Review</b>	Doc. # <b>CDG-00352</b> Page 2 of 9
	<b>Distributed Energy Resources - NYSSIR</b>	Version 1.1 – 8/14/18

**TABLE OF CONTENTS**

<u><b>Section</b></u>	<u><b>Page</b></u>
<b>1.0 INTRODUCTION</b>	<b>3</b>
<b>2.0 EXECUTIVE SUMMARY</b>	<b>3</b>
<b>3.0 COMPANY EPS PARAMETERS</b>	<b>3</b>
<b>4.0 INTERCONNECTION CUSTOMER SITE</b>	<b>4</b>
<b>5.0 SYSTEM IMPACT ANALYSIS</b>	<b>4</b>
<b>6.0 MITIGATIONS FOR SYSTEM IMPACT ANALYSIS FAILURES</b>	<b>7</b>
<b>7.0 CONCEPTUAL COST ESTIMATE</b>	<b>8</b>
<b>8.0 REVISION HISTORY</b>	<b>9</b>

<b>ORANGE &amp; ROCKLAND UTILITIES, INC.</b>	<b>Coordinated Electric System Interconnect Review</b>	Doc. # <b>CDG-00352</b> Page 3 of 9
	<b>Distributed Energy Resources - NYSSIR</b>	Version 1.1 – 8/14/18

## 1.0 INTRODUCTION

This report presents the analysis results of the Orange & Rockland Utilities (“O&R” or the “Company”) interconnection study based on the proposed interconnection and design submittal from the Interconnection Customer. The intent of this report is to assess this project’s feasibility, determine its impact to the existing electric power system (EPS), determine interconnection scope and installation requirements, and determine costs associated with interconnecting the Interconnection Customer’s generation to the Company’s Electric Power System (EPS). This Coordinated Electric System Impact Review (CESIR) study; according to the NYSSIR Section I.C Step 6; identifies the scope, schedule, and costs specific to this Interconnection Customer’s installation requirements.

## 2.0 EXECUTIVE SUMMARY

The total estimated planning grade cost of the work associated with the interconnection of the Interconnection Customer is **\$859,100.**

The interconnection was found to be feasible with modifications to the existing Company EPS and operating conditions, which are described in detail in the body of this Study.

The ability to generate is contingent on this facility being served by the interconnecting circuit during normal Utility operating conditions. Therefore, if the interconnecting circuit is out of service, or if abnormal Utility operating conditions of the area EPS are in effect, the Company reserves the right to disengage the facility.

No future increase in generation output beyond that which specified herein for this interconnection has been studied. Any increase in system size and/or design change is subject to the requirements of the NYSSIR.

## 3.0 COMPANY EPS PARAMETERS

<b>Substation</b>	<b>South Goshen</b>
Transformer Name (list multiple where normally tied to common bus)	Bank 189
Transformer Peak Load (kW)	19011
Contingency Condition Load, N-1 Criteria (kW) (as applicable)	None
[Daytime, 24 hour] Light Load (kW)	4922
Generation: Total, Connected, Queued Ahead (kW)	13266, 1666, 11600
Contingency Condition Generation: Total, Connected, Queued Ahead (kW)	N/A
Supply Voltage (kV)	69
Transformer Maximum Nameplate Rating (kVA)	20,000
Distribution Bus Voltage Regulation ( <a href="#">LTC on substation transformer or voltage regulator at the beginning of a feeder</a> )	No LTC on transformer
Transmission GFOV Status	<b>Not installed</b>

<b>ORANGE &amp; ROCKLAND UTILITIES, INC.</b>	<b>Coordinated Electric System Interconnect Review</b>	Doc. # <b>CDG-00352</b>
	<b>Distributed Energy Resources - NYSSIR</b>	Page 4 of 9 Version 1.1 – 8/14/18

Bus Tie (between transformer banks)	open
Number of Feeders Served from this Bus	3

<b>Connecting Feeder/Line</b>	<b>89-2-13</b>
Peak Load on feeder (kW)	5182
[Daytime, 24 hour] Light Load on Feeder (kW)	1288
Feeder Primary Voltage at POI (kV)	13.2
Line Phasing at POI	3
Circuit distance from POI to substation	7.17 miles
Distance from POI to nearest 3-phase, (if applicable)	0 miles
Line Regulation	Voltage Regulator
Line/Source Grounding Configuration at POI	effective
<b>Other</b> Generation: Total, Connected, Queued Ahead (kW)	5912, 1312, 4600

<b>System Fault Characteristics without Interconnection Customer DG at POI with System Upgrades described in Section 6</b>	
Interconnection Customer POI Location	279 Maple Ave
I 3-phase (3LLL)	2660 Amps (per ph)
I Line to Ground (3I0)	2542 Amps (Max)
Z1 (100 MVA base) use ohm instead	0.9792+ j3.0891 Ohms
Z0 (100 MVA base) use ohm instead	0.8347 + j3.3695 Ohms

#### 4.0 INTERCONNECTION CUSTOMER SITE

The Interconnection Customer is proposing a new primary service connection. The service voltage is 13.2kV. The applicant is proposing to install 5,000kW Solar PV system (CDG-00352). The proposed POC is on feeder 89-2-13 supplied from Transformer Bank\_189 at the South Goshen Substation. The POC is located approximately 7.17 circuit miles from the South Goshen substation.

The proposed generating system consists of:

- Fixed ground mounted solar array with 40 SunGrow inverters
- Total generation capacity is 5000 kW

#### 5.0 SYSTEM IMPACT ANALYSIS

Category	Criteria	Limit	Result
Voltage	Overvoltage	< 105% (ANSI C84.1)	Fail
With the addition of the subject generator the maximum voltage as modeled on the Feeder is 105.7% of nominal.			

<b>ORANGE &amp; ROCKLAND UTILITIES, INC.</b>	<b>Coordinated Electric System Interconnect Review</b>	Doc. # <b>CDG-00352</b> Page 5 of 9
	<b>Distributed Energy Resources - NYSSIR</b>	Version 1.1 – 8/14/18

Voltage	Undervoltage	> 95% (ANSI C84.1)	Pass
With the addition of the subject generator the minimum voltage as modeled on the Feeder is 96.1% of nominal.			
Voltage	Substation Regulation for Reverse Power	<100% minimum load criteria	Fail
The total generation on Feeders 89-1-13, 89-2-13, 89-3-13 is 13.26 MW. The total minimum load on these Feeders is 4.92 MW. Therefore, the generation to load ratio is 269.5%. Will reverse flow the substation transformer regularly during Peak PV production hours.			
Voltage	Feeder Regulation for Reverse Power	<100% Minimum load to generation ratio	Pass
No voltage regulator upstream of proposed project			
Voltage	Fluctuation	<3% steady state from proposed generation on feeder	Pass
Voltage	Fluctuation	<5% steady state from aggregate DER on substation bus (75% generation loss)	Pass
Voltage	Fluctuation	Regulator tap movement exceeds 1 position, generation change of 75% of nameplate rating does not result in voltage change > ½ the bandwidth of any feeder voltage regulating device.	Pass
No voltage regulator upstream of proposed project			
Voltage	Flicker	Screen H Flicker	Fail
The Pst for the location is 0.65 and the limit is 0.35 therefore the proposed project fails the Screen H test. Would need to reduce PV size to 2675 kW to pass.			
Equipment Ratings	Thermal (continuous current)	< 90% thermal limits assuming no load	Pass
The subject generator's full output current is 218 A. No upstream thermal limits are exceeded			

<b>ORANGE &amp; ROCKLAND UTILITIES, INC.</b>	<b>Coordinated Electric System Interconnect Review</b>	Doc. # <b>CDG-00352</b> Page 6 of 9
	<b>Distributed Energy Resources - NYSSIR</b>	Version 1.1 – 8/14/18

Equipment Ratings	Withstand (fault current)	<90% withstand limits	Fail
The additional fault current contribution from the generation contributes to interrupting ratings in excess of existing EPS equipment. The project size would need to be reduced to 3600kVA (however, the flicker screen reduced system size to 2675kW).			
Protection	Unintentional Islanding	Unintentional Islanding Document & Company Guidelines	Pass
The subject generator is a 5 MW PV generation system. It passed SANDIA anti-Islanding screening criteria			
Protection	Protective device coordination	Company Guidelines	Pass
The project will require a DGR. The DGR will coordinate with upstream protective devices.			
Protection	Fault Sensitivity	Rated capabilities of EPS equipment	Pass
No impact from the proposed project.			
Protection	Ground Fault Detection	Reduction of reach > x% (by Utility)	Pass/Fail
The developer hasn't proposed a viable grounding scheme. The grounding shown in the 3LD shows inverter neutrals connected to GSU grounded neutral. However, a review of the inverter manual confirms the proposed inverter doesn't have a neutral.			
Protection	Overvoltage - Transmission System Fault	Company 3V0 criteria	Fail
The generation to load ratio on the serving distribution system has failed the Company's planning threshold in which transmission ground fault overvoltage become an electrical hazard due to the distribution source contribution. An evaluation of the existing EPS has been performed and it has been determined that protection mitigation methods are required.			
Protection	Overvoltage - Distribution System Fault	< 138% voltage rise	Pass
With subject generator interconnected the modeled voltage rise on the unfaulted phases of the system is 125%			
Protection	Effective Grounding	IEEE-142 ( $0 < R_0/X_1 < 1$ ; $0 < X_0/X_1 < 3$ )	Pass
With subject generator interconnected the modeled $R_0/X_1$ is 0.27 PU and the $X_0/X_1$ is 1.09 PU. However, effective grounding isn't achieved because the inverters do not have a neutral (per manufacturer's user manual). A supplemental grounding study is required to size a grounding bank, a zig zag transformer or a neutral grounding reactor.			
SCADA	Required EMS Visibility for Generation Sources	Monitoring & Control Requirements	Yes

<b>ORANGE &amp; ROCKLAND UTILITIES, INC.</b>	<b>Coordinated Electric System Interconnect Review</b>	Doc. # <b>CDG-00352</b> Page 7 of 9
	<b>Distributed Energy Resources - NYSSIR</b>	Version 1.1 – 8/14/18

The 5 MW subject generator triggers the requirement for SCADA reporting to the Utility.			
Other			
[List any unique or other interconnection problems here]			

## 6.0 MITIGATIONS FOR SYSTEM IMPACT ANALYSIS FAILURES

Detail below is intended to provide sufficient information and clarity to give the Interconnection Customer an understanding to the relationship of costs and scope associated with the DER interconnection and the system modifications due to the DER impact. This includes any required EPS equipment upgrades. Where scope items are identified, associated labor, equipment rentals and indirect project support functions (such as engineering and project management) are intended and implied.

Upgrade Required	Failures Addressed
Operate at fixed power factor of 0.99 lagging	Steady-State Overvoltages
Reduce PV size to 2675 kW	Screen H Flicker
Reduce Upper setpoint of Capacitor bank 6873119 to 124V.	Overvoltages and Flicker when Capacitor is ON during light load, high PV output.
3V0 protection at substation for new PV site and other substation upgrades for reverse flow	Substation reverse flows
Reducing PV size to 3600 kW would reduce the fault current increase to <10% and avoid this	>10% change in fault current

Additional details on the scope of each option can be found below:

### Option 1:

The substation upgrades required to facilitate the proposed installation include the following:

- Install 3V0 protection
- Upgrade station LTC controls to work properly with the reverse power flow
- Upgrade the existing substation meter with bi-directional meter

The Distribution upgrades required to facilitate the proposed installation include the following:

- Reduce the project size to 2675 kW due to Flicker. Operate the project at 0.99 PF (consuming VARS). Alternatively, request a time-series flicker study to potentially increase allowable system size
- Conductor from Maple Ave to POI.
- Install smart capacitor
- Install an electronic recloser at PCC

<b>ORANGE &amp; ROCKLAND UTILITIES, INC.</b>	<b>Coordinated Electric System Interconnect Review</b>	Doc. # <b>CDG-00352</b> Page 8 of 9
	<b>Distributed Energy Resources - NYSSIR</b>	Version 1.1 – 8/14/18

- Delay reclosing on the upstream protective devices to 2 seconds to avoid reclosing into live island.

## 7.0 CONCEPTUAL COST ESTIMATE

The following items are a good faith estimate for the scope and work required to interconnect the project estimated under rates and schedules in effect at the time of this study in accordance with the most recent version of the New York State Standardized Interconnection Requirements (“SIR”).

### Planning Grade Estimate

Primary Metering Cluster Installation	\$6,800
Smart Capacitor Installation	\$40,700
New conductors from Maple Ave to PCC (1700 ft.)	\$115,600
Recloser Installation	\$76,000
Commissioning Time Post Installation	\$5,500
Design and Inspections	\$5,000
Monitoring	\$40,000
Contingency (25%)	\$72,400
<b>Total Distribution Estimate</b>	<b>\$362,000</b>

The following table shows the costs for 3V<sub>0</sub> installation:

Engineering, Design, Drafting, Admin	\$48,590
ECC	\$6,500
OH Line	\$29,400
SS Ops – Electricians	\$117,810
SS Ops – Relay Techs	\$96,900
Crane and Rigging	\$2,060
Conduits	\$10,300
Steel	\$1,030
PTs	\$35,700
Relays and Panels	\$41,200
Connectors, Wire, Misc.	\$8,190
Contingency (25%)	\$99,420



<b>ORANGE &amp; ROCKLAND UTILITIES, INC.</b>	<b>Coordinated Electric System Interconnect Review</b>	Doc. # <b>CDG-00352</b> Page 9 of 9
	<b>Distributed Energy Resources - NYSSIR</b>	Version 1.1 – 8/14/18

<b>Total Substation Estimate</b>	<b>\$497,100</b>
----------------------------------	------------------

The total interconnection cost estimate is **\$859,100.**

Notes:

1. These estimated costs are based upon the results of this study and are subject to change. All costs anticipated to be incurred by the Company are listed.
2. The Company will reconcile actual charges upon project completion and the Interconnection Customer will be responsible for all final charges, which may be higher or lower than estimated according to the SIR I.C step 11.
3. This estimate does not include the following:
  - additional interconnection study costs, or study rework
  - additional application fees,
  - applicable surcharges,
  - property taxes,
  - overall project sales tax,
  - future operation and maintenance costs,
  - adverse field conditions such as weather and Interconnection Customer equipment obstructions,
  - extended construction hours to minimize outage time or Company's public duty to serve,
  - the cost of any temporary construction service, or
  - any required permits.
4. Cost adders estimated for overtime would be based on 1.5 and 2 times labor rates if required for work beyond normal business hours. Per Diems are also extra costs potentially incurred for overtime labor.

**8.0 REVISION HISTORY**

<u>Revision</u>	<u>Date</u>	<u>Description of Revision</u>
1.0	04/16/2019	Initial document